

NSW Swimming Pool Register

POOL 'SELF ASSESSMENT' CHECKLIST - INDOOR POOLS



Does your pool meet the safety standards?

Window restrictions for indoor pools

The windows can only open to a maximum of 100mm	<input type="radio"/> Yes	<input type="radio"/> No
OR The windows are totally covered by bars or a metal screen	<input type="radio"/> Yes	<input type="radio"/> No
OR The height from the sill of the lowest opening panel of a window (to the pool area) is at least 1800mm from the floor	<input type="radio"/> Yes	<input type="radio"/> No

Doors that have access to pools

There is a latch on the door at least 1500mm above floor level	<input type="radio"/> Yes	<input type="radio"/> No
Doors open away from the pool area and are self-latching	<input type="radio"/> Yes	<input type="radio"/> No
There are no pet doors or openings greater than 100mm	<input type="radio"/> Yes	<input type="radio"/> No

Wall restrictions for indoor pools

There are no wall openings greater than 100mm	<input type="radio"/> Yes	<input type="radio"/> No
---	---------------------------	--------------------------

Around the pool

There is an appropriate warning sign, including details of resuscitation (CPR) techniques, in the immediate vicinity of the pool area which can be easily read from a distance of 3 metres.	<input type="radio"/> Yes	<input type="radio"/> No
---	---------------------------	--------------------------

If you have answered 'No' to any of the questions above, please contact your local council for further information.

bepoolsafe.com.au / swimmingpoolregister.nsw.gov.au

